

**NOTICE OF FIRE SAFETY INSPECTION
OREGON STATE UNIVERSITY**



Facility Inspected: WEIGAND HALL
 Date Inspected: 15 MAR 207
 Reinspect Date: 24-Apr-07
 Reinspect Time: 9:00 A.M.
 EH&S Rep: PETE

A fire safety inspection of the facility listed above was performed by the Corvallis Fire Prevention Bureau. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection please phone me at 766-6903. Thank you for your cooperation and support for fire safety. *Jim Patton, Fire Prevention Officer, jim.patton@ci.corvallis.or.us*

NOTE **Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

* *Annotates a deficiency identified by OSU Environmental Health & Safety Department. Direct any questions regarding these items to that office (737-2273).*

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action to be completed no later than the reinspection date.

Facility Services Priority Codes:

- Priority 1 – (p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be
- Priority 2 – (p2) items should be corrected within the five-week period before the
- Priority 3 – (p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Andrew Gray (Environmental Health & Safety) at extension 7-7651. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department contact the Customer Service Unit at ext. 7-2969. MS Excel format is available upon request.

Responsible Party	Area	Description	Code Reference
EHS	Fire Extinguishers	Inspect/test in accordance with nationally recognized standards.	
FS-2	Nr. 224	Dumbwaiter - Cover junction box	
DEPT	Rm. 224	Label all chemical containers as to plain language contents.	
DEPT	Rm. 220	Plug power strips directly into outlet. Do NOT chain together.	
DEPT		Label all chemical containers as to plain language contents.	
DEPT	Rm. 224B	Remove glass chemical containers from floor.	
EHS	Rm. 216	Fire extinguisher not required in this area.	
EHS	Rm. 214	Fire extinguisher not required in this area.	
EHS	Rm. 208A	Install a 2A:10BC fire extinguisher in this room.	
DEPT	Rm. 202	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are permitted.	
FS-2	Nr. 200	Repair EXIT sign - NO battery back-up.	

Responsible Party	Area	Description	Code Reference
FS-2	Rm. 115	Upper level - repair EXIT sign - bulb out.	
DEPT	Rm. 242	Install shelf restraints on all shelves that contain chemicals to prevent containers from sliding off shelf.	
DEPT	Rm. 236	Install shelf restraints on all shelves that contain chemicals to prevent containers from sliding off shelf.	
DEPT		Label all chemical containers as to plain language contents.	
DEPT		Move power strip away from compressed gas containers.	
DEPT	Rm. 235	Plug power strips directly into outlet. Do NOT chain together.	
DEPT	Rm. 232	If portable space heater is NOT equipped with a tip-over shut-off switch then remove from building.	
DEPT	Rm. 233	Plug power strips directly into outlet. Do NOT chain together.	
EHS	Left of 233	Repair fire extinguisher cabinet - difficult to open	
DEPT	Rm. 216	Install shelf restraints on all shelves that contain chemicals to prevent containers from sliding off shelf.	
FS-2	Rm. 120	Repair EXIT sign - bulb out.	
DEPT		Discontinue use of non fuse protected extension cord(s) (to power strip) in lieu of permanent wiring. Fuse protected power strips are permitted.	
DEPT	Rm. 13	As the quantity in this room appears to exceed the exempt amounts the room shall be brought to Flammable Storage Room criteria, i.e. fire suppression, venting, etc.. Submit plans to the Corvallis Building Dept. to begin the process.	
EHS	Nr. 13A	Provide a 2A:20BC rated fire extinguisher to protect flammable hazard.	
DEPT	Rm. 8A	Contact EH&S to remove severely oxidized containers.	
DEPT	Rm. 12	Have old chemicals removed if no longer needed.	
DEPT		Install shelf restraints on all shelves that contain chemicals to prevent containers from sliding off shelf.	
FS-2	Rm. 8	Cover fuse blanks in panel	
DEPT	Rm. 5B	Remove hazard signage if no longer applicable	
DEPT	Nr. 4A	Remove electrical appliances from exit way - incubator, etc..	
DEPT	Rm. 16F	Remove portable space heater without tip-over shut-off switch.	
DEPT	Rm. 17	Remove portable space heater without tip-over shut-off switch.	
EHS	Rm. 116	Fire extinguisher not required in this area.	
FS-2	Rm. 120	Remove wood board from circuit panel.	
EHS		Provide a 20 Lb. ABC rated fire extinguisher to protect possible cooking hazards.	
DEPT	Rm. 120A	Remove home made extension cord	
DEPT		Store glass chemical container properly, not on top of material	
DEPT	Rm. 122	Remove glass chemical containers from floor.	
DEPT		Secure high pressure cylinders with something other than twine.	
DEPT		Install shelf restraints on all shelves that contain chemicals to prevent containers from sliding off shelf.	
DEPT		Discard home made duplex extension cord.	
DEPT		Cap all high pressure cylinders not currently in use.	
EHS	Rm. 115	Remount fire extinguisher (panel)	
DEPT	Rm. 114	Install shelf restraints on all shelves that contain chemicals to prevent containers from sliding off shelf.	
DEPT		Discontinue use of non fuse protected extension cord(s) (to power strip) in lieu of permanent wiring. Fuse protected power strips are permitted.	
FS-2	Nr. Rm. 2	Remove edge bolts from exit door.	