

NOTICE OF FIRE SAFETY REINSPECTION
OREGON STATE UNIVERSITY



Facility Inspected:	Agriculture & Life Science Building
Date Inspected:	5-Dec-06
Reinspect Date:	17-Jan-06
Reinspect Time:	1:30 PM
EH&S Rep:	Matt

A fire safety re-inspection of the facility listed above was performed by the Corvallis Fire Prevention Bureau. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection please phone me at 766-6903. Thank you for your cooperation and support for fire safety. *Jim Patton, Fire Prevention Officer, jim.patton@ci.corvallis.or.us*

NOTE	Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.
*	<i>Annotates a deficiency identified by OSU Environmental Health & Safety Department. Direct any questions regarding these items to that office (737-2273).</i>

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible groups and begin corrective action as soon as possible.

	Facility Services Priority Codes:
Priority 1 –	(p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be
Priority 2 –	(p2) items should be corrected within the five-week period before the
Priority 3 –	(p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Andrew Gray at extension 7-7651. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department contact the Customer Service Unit at ext. 7-2969. MS Excel format is available upon request.

Responsible Party	Area	Description	Code Reference
FS-2	Fire Sprinkler System	Inspect/test sprinkler and standpipe system, and fire pump in accordance with nationally recognized standards.	
FS-2	<u>Stairwells</u>	<u>Provide approved stairwell identification signage in all stairwells.</u>	

Responsible Party	Area	Description	Code Reference
DEPT	<u>Corridors</u>	<u>Many doors still being held open in an unapproved manner (wooden & plastic door stops). This is a rated corridor, and as such requires openings such as doorways to be separated from the corridor by self-closing 20 min. rated door. If it is the desire to maintain these doors in an open position, a design professional should be consulted to determine an approved alternative, in the interim these doors shall remained closed.</u>	
DEPT	Chemical Hoods	*Ensure users are advised to NOT raise hood sashes to above that level for which the hoods are approved and labeled.	
FS-2	Standpipe Closets	The closets that contain fire department standpipe connections should remain unlocked for immediate access. If for some valid reason this cannot be done then multiple access keys shall be provided.	
EHS	Fifth Floor	Fire extinguishers due in the penthouse areas.	
DEPT	Rm. 4072	<u>Have wiring to fluorescent lighting fixture redone in an approved manner.</u>	
DEPT	Rm. 4079	Use a non combustible material to chain high pressure cylinders.	
DEPT	Nr. 4121	Remove freezer from corridor. Corridors shall not be used for storage at any time.	
DEPT		Label large plastic dispenser as to plain language contents	
DEPT	Rm. 4021	Reduce the amount of incompatible chemicals from under hood.	
DEPT	Rm. 4120C	Remove homemade duplex extension cord. Listed fuse protected power strip is acceptable.	
FS-2	Rm. 4134	Replace ceiling panel	
FS-2	Rms. 4000	<i>NEW - Cover arrow on EXIT sign to properly reflect direction of exit.</i>	
DEPT	Rm. 4009	Remove halogen lamp that is NOT equipped with a safety screen.	
DEPT	Nr. 4000	Remove filing cabinet from corridor. Corridors shall NOT be used for storage at any time.	
DEPT	Rm. 4028	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT	Nr. H3006	Remove filing cabinet from corridor. Corridors shall NOT be used for storage at any time.	
RECY	Nr. 3073	Remove combustible recycling bags from corridor.	
DEPT	Rm. 3064	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
RECY	Across from 3020	Repair or remove broken recycling container. Lid is broken and won't close properly.	
FS-2	Rm. 3150B	Replace ceiling panel.	
FS-2	Rm. 3134	Replace ceiling panel.	
FS-2	Rm. 3137F	Repair fire sprinkler head. Barely projects through ceiling tile.	
DEPT	Rm. 3119A	Remove glass chemical containers from floor.	
DEPT	Rm. 3110B	Discontinue holding fire door open in an unapproved manner.	
DEPT	Rm. 2110	Discontinue obstructing fire doors. Keep are clear in front of these doors at all times.	
DEPT	Rm. 2114	Complete shelf restraints on all shelves that contain chemicals.	
DEPT	Rm. 2116	Remove glass chemical containers from floor.	
DEPT	Rm. 2119	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable. Cord runs up into the ceiling.	
DEPT		Clear material away from exit ways	
DEPT		Label all chemical containers as to plain language contents/hazards.	

Responsible Party	Area	Description	Code Reference
DEPT	Rm. 2134	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT	Rm. 2023D	Discontinue running power cord through wall.	
DEPT	Rm. 2034	Install shelf restraints on shelves that contain chemicals to prevent containers from sliding off of shelves.	
DEPT	Nr. 2040	Remove bookshelf from corridor. Corridors shall not be used for storage at any time.	
DEPT	Rm. 2053	Remove glass chemical containers from floor.	
DEPT	Rm. 2074	Remove chalkboard from exit way. Or mount on wall so it doesn't fall over and obstruct exit way	
DEPT	Rm. 2023A	Install shelf restraints on shelves that contain chemicals to prevent containers from sliding off of shelves.	
DEPT	Rm. 2035C	Tighten up shelf restraints so that they are effective.	
DEPT	Room 1112	Remove "household use only" toaster oven.	
DEPT		Install shelf restraints on shelves that contain chemicals to prevent containers from sliding off of shelves.	
DEPT	Rm. 1055A	Separate the oxygen and flammable gases by 20' or install a separation wall between the two.	
	Rm. 1055B	Provide access at reinspection	
DEPT	Rm. 1055C	Provide approved shelf restraints on all non-enclosed shelves that contain hazardous chemicals.	
DEPT		Remove containers from aisle.	
DEPT	Rm. 1055D	Adjust shelf restraints to function properly.	
DEPT		Reattach grounding wire.	
DEPT	Near 1055	Post this area "NO SMOKING WITHIN 50 FEET"	
EHS		NEW - Provide a 2A20BC rated fire extinguisher in this area.	
DEPT	Rm. 1081	Install shelf restraints on shelves that contain chemicals to prevent containers from sliding off of shelves.	
DEPT	Rm. 1087	Install shelf restraints on shelves that contain chemicals to prevent containers from sliding off of shelves.	
DEPT		Remove glass chemical containers from floor.	
DEPT	Rm. 1073	Install shelf restraints on shelves that contain chemicals to prevent containers from sliding off of shelves.	
DEPT	Rm. 1065	Install shelf restraints on shelves that contain chemicals to prevent containers from sliding off of shelves.	
DEPT		Remove glass chemical containers from floor.	
DEPT	Rm. 1031	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT	Rm. 1006	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT	Rm. 1154	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT	Rm. 1151	Install shelf restraints on shelves that contain chemicals to prevent containers from sliding off of shelves.	
DEPT	Rm. 1109	Install shelf restraints on shelves that contain chemicals to prevent containers from sliding off of shelves.	
DEPT	Rm. 1120	Remove extension cords to lights in ceiling.	
DEPT	Room 1151	Install shelf restraints on shelves that contain chemicals to prevent containers from sliding off of shelves.	
DEPT	Right of room 82	Stairwell - Remove items from stairwell and cease storing material in stairwells at any time.	

Responsible Party	Area	Description	Code Reference
DEPT	Rm. 85	<u>Secure all high pressure cylinders in an approved manner</u>	
DEPT		<u>Discontinue use of non fuse-protected extension cord in lieu of permanent wiring : listed fuse protected power strips are acceptable.</u>	
DEPT		<u>Discontinue chaining power strips. Power strips shall plug directly into outlet.</u>	
DEPT		Remove glass chemical containers from floor.	
DEPT	Left of 79	Remove desk and other stuff from corridor. Corridors shall not be used for storage at ANY time.	
DEPT	Rm. 62	Discontinue use of non fuse-protected extension cord in lieu of permanent wiring - listed fuse protected power strips are acceptable.	
RECY	Nr. 018	Remove combustible recycling bags from corridor.	