

**NOTICE OF FIRE SAFETY INSPECTION
OREGON STATE UNIVERSITY**



Facility Inspected: Hazardous Waste Facility
 Date Inspected: 6-Dec-06
 Reinspect Date: 18-Jan-07
 Reinspect Time: 9:00 AM
 EH&S Rep: Lance

A fire safety inspection of the facility listed above was performed by the Corvallis Fire Prevention Bureau. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection please phone me at 766-6903. Thank you for your cooperation and support for fire safety. *Jim Patton, Fire Prevention Officer, jim.patton@ci.corvallis.or.us*

NOTE **Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

* *Annotates a deficiency identified by OSU Environmental Health & Safety Department. Direct any questions regarding these items to that office (737-2273).*

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible groups and begin corrective action as soon as possible.

Facility Services Priority Codes:

- Priority 1 – (p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be
- Priority 2 – (p2) items should be corrected within the five-week period before the
- Priority 3 – (p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Bryan McCampbell at extension 7-2505. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department contact the Customer Service Unit at ext. 7-2969. MS Excel format is available upon request.

Responsible Party	Area	Description	Code Reference
EHS		Fire extinguishers are due	
EHS		Discontinue running extension cord under door. Use a power strip and not under door.	
EHS	Flammable Rm.	Discontinue use of non rated pump in this room.	
EHS	Fire Sprk. Syst Storage Rms	Provide approved grounding and bonding to plastic drums	
FS-2		Fire sprinkler system due.	
EHS		Some rooms have containers on shelves that are not in tubs or have shelf restraints installed. Please choose one of these options.	