

**NOTICE OF FIRE SAFETY INSPECTION  
OREGON STATE UNIVERSITY**



Facility Inspected: Nash Hall  
 Date Inspected: 11-Apr-07  
 Reinspect Date: 22-May-07  
 Reinspect Time: 9:00 a.m.  
 EH&S Rep: Matt

A fire safety inspection of the facility listed above was performed by the Corvallis Fire Prevention Bureau. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection please phone me at 766-6903. Thank you for your cooperation and support for fire safety. *Jim Patton, Fire Prevention Officer, jim.patton@ci.corvallis.or.us*

**NOTE** **Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

\* *Annotates a deficiency identified by OSU Environmental Health & Safety Department. Direct any questions regarding these items to that office (737-2273).*

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible groups and begin corrective action as soon as possible.

Facility Services Priority Codes:

- Priority 1 – (p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be
- Priority 2 – (p2) items should be corrected within the five-week period before the
- Priority 3 – (p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Andrew Gray at extension 7-7651. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department contact the Customer Service Unit at ext. 7-2969. MS Excel format is available upon request.

Responsible Party	Area	Description	Code Reference
FS-2	Fire Sprinkler System	Inspect and test system in accordance with nationally recognized standards.	
FS-2	<b><u>Fire Alarm</u></b>	<b><u>Add "Water Flow Alarm" to the annunciator panel in the hallway and main panel.</u></b>	
<b><u>FS-2</u></b>	<b><u>Standpipe system</u></b>	<b><u>Conduct an annual inspection/maintenance on standpipe system in accordance with nationally recognized standards.</u></b>	
DEPT	Rm. 526	Label all chemical containers one gallon or larger as to plain language contents. All chemical containers should be labeled.	
DEPT	Rm. 516	Reduce quantity of flammable material outside of an approved cabinet or room to 10 gallons or less.	
DEPT	Rm. 502D	Secure all high pressure cylinders in an approved manner.	
FS-2	Nr. 504	Circuit Panel - Label all circuits.	

Responsible Party	Area	Description	Code Reference
DEPT	Rm. 328	Provide approved shelf restraints on all elevated shelves that contain hazardous substances.	
DEPT	Nr. 323	Remove table from hallway. Keep hallways clear at all times.	
DEPT	Rm. 350	Reduce the quantity of flammable gas to that which is in use. Additional tanks shall be stored in an approved storage room.	
EHS	Rm. 256	Fire extinguisher due. Not required in this area. BC only!	
DEPT	Rm. 224	Cap all high pressure cylinders	
DEPT		Label all chemical containers one gallon or larger as to plain language contents. All chemical containers should be labeled.	
FS-2	Rm. 204	As this room is only provided with one exit the student load shall be capped at 49 and the scheduling office shall be made aware of this restriction so the room will not be scheduled for more. Post room with occupant load.	
<b>DEPT</b>	<b>Rm. 202</b>	<b><u>Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Listed power strip is acceptable.</u></b>	
FS-2	Rm. 100	Emergency lighting backup system due.	
FS-2	Exterior Flammable Storage Rm.	Ensure ventilation fan is functioning properly	
DEPT		If dispensing is occurring AT ALL, provide approved grounding and bonding	
EHS		Fire Extinguisher is due	
<b>DEPT</b>	<b>Rm. 142</b>	<b><u>Plug power strips directly into outlet. Do NOT chain them together or use them along with a non fuse protected extension cord.</u></b>	
<b>DEPT</b>	<b>Rm. 134</b>	<b><u>Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Listed power strip is acceptable.</u></b>	
DEPT	Rm. 124	Dispense flammable material within an approved hood and provide grounding and bonding.	
FS-2	Rm. 16	Remove plastic covers on light fixtures, or discard unit for safety. They appear to be melting from the heat.	
<b>DEPT</b>	<b>Rm. 26</b>	<b><u>Remove 3-plex device. A listed/fuse protected power strip is acceptable.</u></b>	
<b>DEPT</b>	<b>Near 26</b>	<b><u>Remove items from hallway. Hallways are not to be used for storage at any time.</u></b>	
DEPT	Rm. 22	Remove load from fire sprinkler pipes.	
DEPT	Nr. 40	Remove material from hallway. CLEAR THE HALLS PROGRAM!	
DEPT	Nr. 38	Remove material from hallway. CLEAR THE HALLS PROGRAM!	
DEPT	Rm. 32A	Dispense flammable material within an approved hood and provide grounding and bonding.	
EHS	Rm. 46	Fire extinguisher due. Not required in this area.	
DEPT	Nr. 58	Remove material from hallway. CLEAR THE HALLS PROGRAM!	
FS-2		Circuit Panel - Cover blanks in panel	