

**NOTICE OF FIRE SAFETY INSPECTION  
OREGON STATE UNIVERSITY**



Facility Inspected: Dixon Recreation Center  
 Date Inspected: 2-May-07  
 Reinspect Date: 7-Jun-07  
 Reinspect Time: 9:00 a.m.  
 EH&S Rep: Pete

A fire safety inspection of the facility listed above was performed by the Corvallis Fire Prevention Bureau. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection please phone me at 766-6903. Thank you for your cooperation and support for fire safety. *Jim Patton, Fire Prevention Officer, jim.patton@ci.corvallis.or.us*

**NOTE** **Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

\* *Annotates a deficiency identified by OSU Environmental Health & Safety Department. Direct any questions regarding these items to that office (737-2273).*

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible groups and begin corrective action as soon as possible.

Facility Services Priority Codes:

- Priority 1 – (p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be
- Priority 2 – (p2) items should be corrected within the five-week period before the
- Priority 3 – (p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Andrew Gray at extension 7-7651. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department contact the Customer Service Unit at ext. 7-2969. MS Excel format is available upon request.

Responsible Party	Area	Description	Code Reference
DEPT	Fire Alarm	Have inspection label attached to annunciator panel by front door.	
DEPT	Main Gym	Work toward installing an EXIT sign over the SW corner exit opening as the sign over the actual doors is not clearly visible from within the gym.	
DEPT	Grd. Flr. NW Exit	Nr. Small weight room - EXIT Exterior, Clear back vegetation and provide a safe and smooth egress path to open area. Paved or rock is preferred.	
DEPT		Nr. Small weight room - Remove tables from hall.	
EHS	Old Gym	Provide Fire Extinguisher signs on wall to identify extinguishers in hallway.	
DEPT	Main Weight Rm.	Remove obstruction to exit (Weight equipment). Corrected on the spot.	
DEPT	Basement	Remove combustible material from HVAC equipment. Store away from equipment.	

Responsible Party	Area	Description	Code Reference
DEPT		Discontinue holding fire doors open.	
<u>DEPT</u>		<u>Investigate the potential to provide a second means of escape from this basement. Dead-end exceeds 300'. In the interim ensure additional safety precautions are employed while working in this far back area.</u>	