

NOTICE OF FIRE SAFETY INSPECTION

OREGON STATE UNIVERSITY



Facility Inspected:	Weniger Hall
Date Inspected:	14-Jun-07
Reinspect Date:	24-Jul-07
Reinspect Time:	9:00 a.m.
EH&S Rep:	Lance

A fire safety inspection of the facility listed above was performed by the Corvallis Fire Prevention Bureau. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection please phone me at 766-6903. Thank you for your cooperation and support for fire safety. *Jim Patton, Fire Prevention Officer, jim.patton@ci.corvallis.or.us*

NOTE	Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.
*	<i>Annotates a deficiency identified by OSU Environmental Health & Safety Department. Direct any questions regarding these items to that office (737-2273).</i>

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible groups and begin corrective action as soon as possible.

Facility Services Priority Codes:	
Priority 1 –	(p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be
Priority 2 –	(p2) items should be corrected within the five-week period before the
Priority 3 –	(p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Andrew Gray at extension 7-7651. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department contact the Customer Service Unit at ext. 7-2969. MS Excel format is available upon request.

Responsible Party	Area	Description	Code Reference
DEPT	Yellow Caution Placards	ALL DEPT. - Ensure each yellow hazards placard has been updated	
FS-2	<u>Standpipes</u>	<u>Inspect and test dry standpipes in accordance with nationally recognized standards.</u>	
FS-2	Roof	<u>South Standpipe - Right hand connection - very tight.</u>	
FS-2		<u>West upper standpipe - middle connection - tighten bolt.</u>	
FS-2		Elevator Rm. - Fire extinguisher due	
FS-2		E/NE Corner of upper roof near standpipe connection - HVAC fan making noise - investigate and service as needed.	
FS-2		E/NE Standpipe connection - Loose bolt. Check ALL roof standpipe connections and adjust/repair as needed.	
	<u>Near</u>		
	<u>Flammable</u>		

Responsible Party	Area	Description	Code Reference
EHS	Storage Rm.	Provide a 2A:20BC extinguisher.	
EHS	Nr. 615	Adjust fire extinguisher cabinet to open more easily. Thumb latch is difficult to grab to open.	
FS-2	Rm. 609	*Remove timer switch on light fixture.	
DEPT	Nr. 602	Discontinue holding fire door open in unapproved manner.	
DEPT	Rm. 538	*Replace cap to unattended open container under hood.	
DEPT	Rm. 540	Secure nitrogen tank in approved manner.	
RECY	Across 561A	Remove combustible recycling bags from exitway.	
DEPT	Rm. 540	*remove obstruction to eye wash station.	
DEPT	Rm. 542	Secure nitrogen tank in approved manner.	
DEPT	Rm. 567	provide shelf restraints on all shelves that contain chemicals.	
DEPT	Rm. 504A	Cap all high pressure cylinders not in use	
DEPT		Secure all high pressure cylinders.	
FS-2	Rm. 504B	Replace cover plate to junction box on wall.	
DEPT	Rm. 506	remove all chemical containers from floor.	
EHS	Rm. 508	*Asbestos hood.	
DEPT	Rm. 508A	Label all chemical containers over 1 gallon as to plain language contents. All containers should be labeled.	
FS-2	Rm. 514	Replace cover plate to junction box on ceiling.	
DEPT	Rm. 518	Cap all high pressure cylinders not in use	
DEPT	Rm. 420	Label all chemical containers over 1 gallon as to plain language contents. All containers should be labeled.	
DEPT	Rm. 422	Label all chemical containers over 1 gallon as to plain language contents. All containers should be labeled.	
DEPT		Secure all high pressure cylinders.	
DEPT	Across 495	Remove materials from hallway. Hallways shall NOT be used for storage at any time.	
DEPT	Right of 400	Remove materials from hallway. Hallways shall NOT be used for storage at any time.	
DEPT	Nr. 408	Remove refrigerator from hallway.	
FS-2	Rm. 414	Cover blanks in circuit panel	
DEPT		Label all chemical containers over 1 gallon as to plain language contents. All containers should be labeled.	
EHS		Relocate to near exit or remove fire extinguisher.	
DEPT	Rm. 416A	Provide shelf restraints on all shelves that contain chemicals.	
DEPT	Rm. 418	Label all chemical containers over 1 gallon as to plain language contents. All containers should be labeled.	
DEPT	Rm. 475	Secure ALL high-pressure cylinders.	
DEPT		Cap all high pressure cylinders not in use	
DEPT		Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT		*Label gas cabinet on the outside as to type of gas.	
DEPT	SHOP	Provide at least 30" access to and around circuit panel.	
DEPT		*Contact EH&S regarding the use of respirators	
DEPT	Rm. 481	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT		Discard power strip which has been rewired with orange extension cord wiring.	
RECY	Across 483	Repair or discard broken recycling container.	
DEPT	Rm. 487	Discard home made 4-plex extension cord.	
DEPT		Remove all chemical containers from floor.	

Responsible Party	Area	Description	Code Reference
DEPT	Across 495	Remove materials from hallway. Hallways shall NOT be used for storage at any time.	
DEPT	Right of 400	Remove materials from hallway. Hallways shall NOT be used for storage at any time.	
DEPT	Nr. 408	Remove refrigerator from hallway.	
DEPT	Rm. 414	Cover blanks in circuit panel	
DEPT		Label all chemical containers over 1 gallon as to plain language contents. All containers should be labeled.	
EHS		Relocate to near exit or remove fire extinguisher.	
DEPT	Rm. 416A	Provide shelf restraints on all shelves that contain chemicals.	
DEPT	Rm. 418	Label all chemical containers over 1 gallon as to plain language contents. All containers should be labeled.	
DEPT	Rm. 308	Cap all high pressure cylinders.	
DEPT	Rm. 308A	Discontinue plugging power strip into power strip. Power strips shall plug directly into outlet.	
DEPT		Remove portable space heater not equipped with tip-over shut-off switch.	
DEPT		Recommend removing chemicals from this office and placing in an approved lab.	
DEPT	Nr. 306	Remove materials from hallway. Hallways shall NOT be used for storage at any time.	
DEPT	Rm. 301	Remove portable space heater if NOT equipped with a tip-over shut-off switch.	
DEPT		Discard power strip that has been rewired with extension cord wiring.	
RECY	Across 371	Repair or remove (2) broken recycling containers that will not close unaided or fully.	
RECY	Across 369	Remove combustible recycling bags from exitway	
DEPT	Rm. 349	Provide approved ventilation for anhydrous ammonia, and appropriate placarding or remove cylinder if no longer needed.	
EHS	Left of 341	Replace fire extinguisher. Low pressure.	
DEPT	Rm. 330	Remove butane tank if no longer utilized. May be due hydrostatic testing.	
DEPT	Rm. 324B	Provide approved shelf restraints to prevent chemical containers from sliding off shelf.	
DEPT	Rm. 320	Provide approved shelf restraints to prevent chemical containers from sliding off shelf.	
DEPT		Remove glass chemical containers from floor.	
DEPT	Rm. 318D	Provide approved shelf restraints to prevent chemical containers from sliding off shelf.	
DEPT	Rm. 318	Remove chemical containers from floor.	
DEPT		Provide approved shelf restraints to prevent chemical containers from sliding off shelf.	
DEPT	Rm. 314	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT	Rm. 241	Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT	Nr. 231	Remove all items from hallway. Hallways shall not be used for storage at any time.	
DEPT	Nr. 230	Remove all items from hallway. Hallways shall not be used for storage at any time.	
DEPT		Secure all high pressure cylinders.	
DEPT		Cap all high pressure cylinders	

Responsible Party	Area	Description	Code Reference
DEPT	Rm. 218	Provide approved shelf restraints to prevent chemical containers from sliding off shelf.	
DEPT	Rm. 210B	Discard home made 4-plex extension cord.	
EHS	Rm. 216	Fire extinguisher on floor. Not required in this area.	
DEPT		Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT	Behind Lecture Halls	Remove obstructions in hallway and keep clear at all times. Keep lights on when lecture halls are occupied.	
FS-2	Rm. 151	Repair EXIT/Emergency light SW151. Bad battery.	
FS-2		Remove obstruction to exit - overhead projector	
RECY	Nr .151	Remove combustible recycling bags from exitway.	
	Rm. 153	Lecture Hall - Discontinue holding doors open with chairs. Chairs also create an exitway obstruction. Spare chairs shall be removed from this area.	
DEPT	Nr. 149	Secure IRAM locker in exitway.	
DEPT	Rm. 120	Remove home made extension cord.	
EHS		CO2 extinguisher due hydro. Not required in this area.	
DEPT		Discontinue use of non fuse protected extension cord in lieu of permanent wiring. Fuse protected power strips are acceptable.	
DEPT	Rm. 118	Discard home made 4-plex extension cord.	
RECY	Across 112	Remove combustible recycling bags from exitway.	
DEPT	Rm. 104	Discontinue plugging power strip into power strip. Power strips shall plug directly into outlet.	
DEPT	Left of 103	Remove bookshelf from hallway. Items shall NOT be stored in hallways at any time.	
FS-2	Rm. 103	Replace cover plate to outlet	
DEPT	Across 105	Remove material from hallway. Keep hallways clear at all times.	
FS-2	Exterior West Side	Provide approved signage indicating "DRY STDP CONNECTION" on the exterior of the stairwell brick structure to as to identify the obscured standpipe connections. If unsure of mounting location contact Jim Patton.	